



Government Of West Bengal
Office Of The Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services
C. R. Das Road, P.O.+P.S. :- Berhampur, Pin :- 742101

Memo no.:FSR/0125186210900019

Date: 10-01-2023

From:

Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services

To: SHYAMANGINI KUNDU COLLEGE OF EDUCATION

Plot No-12265,12266 ,JL No-107,Mouza-Talibpur,Vill-Kaggram,PO-Salar,PS-Salar,Dist-Murshidabad,Pin-742401.

Sub: Fire Safety Certificate for the Existing construction of G+II storied under group Educational Building, in the style 'SHYAMANGINI KUNDU COLLEGE OF EDUCATION at premises no:- Plot No-12265,12266 ,JL No-107,Mouza-Talibpur,Vill-Kaggram,PO-Salar,PS-Salar,Dist-Murshidabad,Pin-742401

This is in reference to your application no. 0125189220900096 dated 24-11-2022 regarding the Fire Safety Certificate for the Existing construction of G+II storied under group Educational Building, in the style 'SHYAMANGINI KUNDU COLLEGE OF EDUCATION at premises no:- Plot No-12265,12266 ,JL No-107,Mouza-Talibpur,Vill-Kaggram,PO-Salar,PS-Salar,Dist-Murshidabad,Pin-742401

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

To up-keep the Fire Safety Measures of the aforesaid building the following safety measures need to be incorporated / maintained:

1. Another 5000 ltr OHWR to be provided for fire fighting purpose.
2. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
3. Entrances / Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
5. A fire control room including a closed-circuit TV system shall have to be installed which observe all the floors of the building.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
7. The employees and security staff shall be conversant with installed firefighting equipment's of the building and to operate

in the event of fire and testing.

8. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

9. A crew of trained Firemen shall be maintained round the clock for fire safety of the building.

10. First Aid firefighting system shall be provided as per I.S. specifications.

11. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.

12. Periodical flashing of water in the Hydrants Pipelines shall be made to maintain the efficient working performance of above-mentioned system.

13. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.

14. This Fire Safety Certificate is valid for Three Years and has to be renewed from the date of issue of this letter.

15. The Fire Safety Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Signature Not Verified

Digitally Signed
Name: SUBRATA GUPTA
Date: 10-Jan-2023 14:46:17
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services